



CERTIFICATE NO.:CNJZ20220905

CERTIFICATE OF ANALYSIS (R407C)

MANUFACTURE DATE: Sept.01st.2022.

INSPECTION DATE: Sept.05th.2022.

BATCH NO.: JZ20220905

PACKAGE: Net11.3KG/CYLINDER

Items	Reporting Units	R-407C Standard	Result
Appearance	/	Colorless, Not cloudy	Conform
Odor	/	No strange stench	Conform
Purity	% \geq	99.9	99.98
Refrigerant Components	N/A	R-32/125/134a	R-32/125/134a
Nominal Comp	%by weight	23/25/52	23.46/24.74/ 51.80
Allowable Comp	%by weight	21-25/23-27/50-54	
The volume fraction of a noncondensable gas	(25°C) \leq	1.5	0.99
Critical Temperature	°C	86.0	Pass
Moisture	% by weight \leq	0.001	Pass 0.0075
High Boiling Residue	% by volume \leq	0.005	Pass
Particulates/Solids	Visually clean to pass	Pass	Pass
Acidity	% by weight (as HCl) \leq	0.0001	Not Detected

Conclusion: Premium Grade.

检验者 Inspector :柯玲

复检者 Review :冯必园

审核者 Checker :王苏玲

浙江锦泽制冷有限公司
ZHEJIANG JINZE REFRIGERANT CO.,LTD.