



浙江锦泽制冷有限公司

ZHEJIANG JINZE REFRIGERANT CO.LTD

CERTIFICATE NO.:CNJZ20220910

CERTIFICATE OF ANALYSIS (R22)

MANUFACTURE DATE: Sept.08th.2022.

INSPECTION DATE: Sept.10th.2022.

BATCH NO.: JZ20220910

PACKAGE: Net13.6KG/CYLINDER

Items	Reporting Units	R-22	Result
Purity	% ≥	99.9	99.96
Boiling Point	°C@101.3kpa	-40.8	Pass -40.8
Boiling Point Range	K	0.3 0.5	Pass 0.28 0.49
Critical Temperature	°C	96.20	Pass 96.20
Isomer Content	%by weight≤	N/A	Pass N/A
Air and Other Non Condensables	% by volume@25.0 °C≤	1.5	Pass 0.8
Water (H2O)	ppm by weight≤	10	Pass 6
All Other Volatile Impurities	% by weight≤	0.5	Pass 0.2
High Boiling Residue	% by volume≤	0.01	Pass 0.002
Particulates/Solids	Visually clean to pass	Pass	Pass
Acidity	ppm by weight (as HCl) ≤	1.0	Pass Undetected
Chloride	No visible Turbidity	Pass	Pass

Conclusion: Premium Grade.

检验者 Inspector :柯玲

复检者 Review :冯必园

审核者 Checker :王苏玲

浙江锦泽制冷有限公司  
ZHEJIANG JINZE REFRIGERANT CO.,LTD.