



浙江锦泽制冷有限公司
ZHEJIANG JINZE REFRIGERANT CO.LTD

CERTIFICATE NO.:CNJZ2212131

CERTIFICATE OF ANALYSIS (R410a)

MANUFACTURE DATE: Dec.10th,2022.

INSPECTION DATE: Dec.13rd,2022.

BATCH NO.:JZ2212131

PACKAGE: Net11.3KG/CYLINDER

Items	Reporting Units	R-410a Standard	Result
Appearance	/	Colorless,transparent,clear and odorless liquid	Conform
Mass fraction of R32	%	48.5-50.5	49.6
Mass fraction of R125	%	49.5-51.5	50.4
Mass fraction of R410a	% $\geq$	99.5	99.98
Mass fraction of moisture	% $\leq$	0.001	0.0009
Mass fraction of acidity (as HCL)	% $\leq$	0.0001	undetected
Mass fraction of evaporated residue	% $\leq$	0.01	0.0007
Determination of chlorides (CL-)	/	Pass	Pass
Volume fraction of non-condensable gases at 25°C	% $\leq$	1.5	0.56

Conclusion: Premium Grade.

浙江锦泽制冷有限公司
ZHEJIANG JINZE REFRIGERANT CO.,LTD.

检验者 Inspector :柯玲

复检者 Review :冯必园

审核者 Checker :王苏玲